

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
FAILURE TO COMPLETE CORRECTIVE ACTIONS**

CAMERON WATER, WV3302603

V#2021-391008

Our water system violated State drinking water requirement. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation.

An on-site evaluation of our system is conducted on a regular basis. Results of the evaluation show significant deficiencies in our water system which must be addressed to the Office of Environmental Health Services-District Office. We did not correct these deficiencies by the required date and are therefore in violation.

What should I do?

There is nothing you need to do at this time.

Required Corrective Action

Failure to correct significant deficiencies
Deficiency: DLEK- water unaccountability
Deficiency: DLEK- leak detection
Deficiency: DCCS – implementation of cross
Connection backflow prevention program
Deficiency: OPR3 – operator coverage
Deficiency: FOTR – ST001, Storage Tank repairs
Deficiency: MCP1 – items remaining from previous
Survey

Corrective Action Required by:

03/20/2021

What happened? What is being done? (Describe corrective action)

Working with Rural Water to assist in finding leaks. Cross Connection and Backflow Prevention Program is moving forward, but not 100% yet.

Published Legal Notice taking applications for Class II WV State Certified Water Plant Operator.

Applied for assistance to update and complete maintenance for our Water Plant.

Completed application for Congressionally Direct Spending Request (EARMARK) submitted thru Charleston, West Virginia

For more information, please contact Nichole M. Bryan at 304-686-2366
or 44 Main Street Cameron, WV 26033

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by CAMERON WATER
State Water System ID# WV3302603

Date Distributed November 30, 2021